

Before

Laboratory report

Customer number 22397

Perstorp Chemicals Ltd.

Bruchhausener Strasse 2

59759 Amsberg

Sales manager: Wohlgemuth, Wolfgang

System number LC63877

Turbine, large

AEG

BP Turbinol 46

Filling date 01.10.2008

Filling amount 2.500 l

Comment

The oil shows a mixture or contamination with calcium (28 mg/kg), zinc (17 mg/kg), and phosphor (34 mg/kg).

All other measured data show a still further usable condition, but the water separation ability and the foam test could not be carried out because there is not enough sample material (please send 1 liter of oil for turbine oil analyses).

An oil change is recommended due to the contamination.

Product number

Sampling

Date of receipt

Oil operating hours

Appearance

[-] visual

Color

[-] DIN ISO 2049

Kin. viscosity at 40°C

[mm²/s] DIN 51366

Neutralization number (acidic)

[mg KOH/g] DIN 51558-1

Water content

[ppm] DIN 51777-1

Oxidation/aging (IR)

[A/cm] DIN 51451/CIP

IRON

[ppm] ICP

Aluminium

[ppm] ICP

Chrome

[ppm] ICP

Copper

[ppm] ICP

Nickel

[ppm] ICP

Lead

[ppm] ICP

Silicon
 [ppm] ICP
Tin
 [ppm] ICP
PQ index
 [-] -

TL5985	TL5368	TL5037
402677	402677	402677
22.12.2010	14.09.2010	23.06.2010
29.12.2010	20.09.2010	26.07.2010
	14000	
0	2	2
4,5	3,0	4,0
45,99	47,71	46,78
0,12	0,07	0,10
9	3735	7563
< 1,0	< 1,0	< 1,0
5	< 1	< 1
< 1	< 1	< 1
< 1	< 1	< 1
< 1	< 1	< 1
< 1	< 1	< 1
< 1	< 1	< 1
1	< 1	1
< 1	< 1	< 1
< 1	< 1	< 1
3	2	2

The given values are based on the individual examined sample and on the application and operating conditions given to us. Please note that the application and operating conditions were not checked by us. The given values can vary in the case of changes of the application and operating conditions.

Laboratory report

Customer number 22397

System number LC63877

Turbine, large

Particle analysis (4µm / 6µm / 14µm)

[Classification according to ISO 4406]
ISO 4406

Phen. antioxidants (IR)

[%] DIN 51451/CIP

Air separation ability (50°C)

[min] DIN ISO 9120

Foaming behavior (Seq.1/25°C)

[ml] ISO 6247

Water separation ability

[s] DIN 51589-1

TL5985	TL5368	TL5037
21/19/16	22/22/22	22/22/22
74,00	100,00	93,00
4	4	4
x	360/0	80/0
x	150	120

The given values are based on the individual examined sample and on the application and operating conditions given to us. Please note that the application and operating conditions were not checked by us. The given values can vary in the case of changes of the application and operating conditions.

Afterwards

Evaluation – oil analysis

Sample number | 201306011 | **Sampling** | 10.06.2013

Construction | | **System** | PERGES | Perstorp, whole location

System position | Turbine 2 | Turbine 2

Maintenance position | Turbine 2 | Lubrication point | Turbine | S-No. | 156

Sampling point | Oil tank

Analysis program | AS2, pump, gear | oil data | Turbinol X-EP 46

Inspection dates | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec

Summary

Evaluation : The oil is in an operative condition

Advice : No further action is necessary

Wear : The amount of wear metals is not yet notable

Evaluation of the analysis parameters

[+] The visual appearance is okay

[+] The kinematical viscosity is okay

[+] The chemical composition (IR) of the oil does not show any noteworthy deviations

[+] The oxidation stability (Ox) is okay

[+] The oxidation- and aging condition (NZ) is okay

[+] The water content (H2O) is sufficiently low

[+] The proportion of elements in the ICP analysis shows no abnormalities

[+] The additivation is okay

[+] The PQ index (PQ) is okay

Advice

None

For questions on the evaluation

Peter Segschneider, B.1091- PB14

peter.segshneider@evonik.com

T.02365/49-5536, F.-19645

